

NCE Services

April 13, 2016

Mr. Al Daniels
Head of Bldgs. & Grds.
Edwards-Knox Central School District
PO Box 630
Hermon, New York

Re: 2016 Fire Inspections

Dear Mr. Daniels:

I have completed the fire inspections of all the buildings in the district and the following violations were noted. It is required that these violations be corrected in order to receive a certificate of occupancy.

Main Building


1. Item 2E2 Blocked rescue window in room 112.
2. Item 10A2 Exit directions missing in 101A.

Bus Garage – no violations noted.

Biomass Boiler – No violations noted.

Please advise me as to the date of the board meeting for the presentation of this report. You need to notify the public and the fire department as to the time and date of this meeting.

Sincerely yours,


John Warneck

36173 NYS Rt. 12E Clayton, New York 13624
315-654-5077

NCE Services

April 13, 2016

Invoice

Per our agreement to provide the 2016 SED Fire Inspection of the
Edwards-Knox Central School District buildings.

Total now due \$550.00

36173 NYS Rt. 12E Clayton, New York 13624
315-654-5077

No Problems Noted

Part II: Public School Fire Safety Non-Conformance Report Sheet

School District Edwards-Knox (SD)
 Facility # _____

Building Name Biomass Boiler

Part II-A (to be completed for public schools only - except "Big 4")					Part II-B					Part II-B					Part II-B				
Item #	Non-Conformance	Date Corrected	Date Reinspected		Item #	Non-Conformance	Date Corrected	Date Reinspected		Item #	Non-Conformance	Date Corrected	Date Reinspected		Item #	Non-Conformance	Date Corrected	Date	
01A-2					08A-2					120-2					19E-1				
01B-1					08B-2					13A-2					19F-1				
01C-1					08C-2					13B-2					19G-1				
01D-1					08D-2					14A-2					19H-2				
01E-1					08E-2					14B-2					20A-1				
02A-2					09A-2					14C-2					20B-1				
02B-1					09B-2					14D-1					20C-1				
02C-3					09C-1					14E-1					21A-3				
02D-1					09D-1					15A-2					22A-3				
02E-2					09F-2					15B-1					22B-3				
02F-3					09G-2					15C-2					22C-3				
02G-2					10A-2					15D-2					23A-1				
03A-3					10B-2					16A-2					23B-1				
03B-1					10C-1					16B-2					23C-1				
04A-2					10D-1					17A-3					23D-2				
04C-1					11A-2					17B-2					24A-3				
05A-3					11B-1					17C-2					25A-3				
05B-2					11C-2					17D-2									
05C-2					11D-2					17E-1									
6A-1					11E-1					17F-3									
06C-1					12A-1					17G-1									
06E-3					12B-3					17H-2									
06F-1					12C-2					17I-2									
06G-1					12D-2					17J-1									
06H-2					12E-1					17K-1									
07A-3					12F-1					17L-1									
07B-2					12G-1					18A-2									
07C-2					12H-1					18B-2									
					12I-1					18C-2									
					12J-1					18D-2									
					12K-1					19A-3									
					12L-1					19B-2									
					12M-1					19C-1									
					12N-1					19D-1									

If any additional non-conformances are observed, check item 25A-3 and list the Code section below.

Inspector
 The Inspector has been provided with a copy of the previous year's school fire safety report:
 Yes No

All schools complete Section 8 only if the building has electrically-operated folding partitions.

Initial Inspection:
 Fire Safety Inspector: Name John Warneck

Date 4/12/15

Registry # 0487-7547B (26E-4)

Final Inspection (if required):
 Fire Safety Inspector: Name _____

Date _____

Registry # _____ (26F-4)

Part III: Public School Certifications

Section III-A. Fire Inspector

The individual noted below inspected this building and the information in this Fire Safety Report represents, to the best of their knowledge and belief, an accurate description of the building and conditions they observed. The individual that performed this inspection has maintained their certification requirements pursuant to Title 19 Part 1208

Name: John Warneck

Telephone #: (315) 654-5077

Title: Consultant

Registry # 0487-7547B
(as designated by the NYS Secretary of State)

Section III-B. Building Administrator or Designee

The individual noted below certifies that this building was inspected on _____ (date) as indicated in Section III-A above.

Name: _____

Telephone #: () _____

Title: _____

Section III-C. School Superintendent

I hereby submit this fire inspection report on behalf of the Board of Education and certify that:

1. Public notice of report availability has been published, and that
2. Any nonconformances noted as corrected on the *Public School Fire Safety Non-Conformance Report Sheet* portion of this report were corrected on the date indicated, and that
3. For any uncorrected nonconformances that appear on this report, the Board of Education or Board of Trustees, at the meeting held pursuant to Section 807-a of the State Education Law, adopted a written plan of correction for those nonconformances, and such plan is available for public scrutiny.

Name: _____

Telephone #: () _____

Title: _____

Electronic Signature (via NYSED Portal)