



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J2D1474

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: Lead Testing 2016

Fred Hauck
20104 NYS ROUTE 3
Watertown, NY 13601

Project / PO Number: N/A
Received: 04/26/2022
Reported: 05/16/2022

Analytical Testing Parameters

Table with 4 columns: Client Sample ID, Sample Matrix, Lab Sample ID, Collected By, Collection Date. Values include 7-B, Drinking Water, J2D1474-01, client, 04/20/2022 10:01.

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead with result <0.0010.

Table with 4 columns: Client Sample ID, Sample Matrix, Lab Sample ID, Collected By, Collection Date. Values include 13-B, Drinking Water, J2D1474-02, Client, 04/20/2022 10:20.

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead with result 0.0076.

Table with 4 columns: Client Sample ID, Sample Matrix, Lab Sample ID, Collected By, Collection Date. Values include 9, Drinking Water, J2D1474-03, Client, 04/20/2022 9:44.

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead with result 0.0027.

Table with 4 columns: Client Sample ID, Sample Matrix, Lab Sample ID, Collected By, Collection Date. Values include 23-B, Drinking Water, J2D1474-04, client, 04/20/2022 10:40.

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead with result 0.0026.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J2D1474

<b>Client Sample ID:</b> 27-B	<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2022 10:42
<b>Lab Sample ID:</b> J2D1474-05	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0014	0.015 AL	0.0010	mg/L		05/02/22 1326	05/02/22 1450	MMC

<b>Client Sample ID:</b> 92	<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2022 10:00
<b>Lab Sample ID:</b> J2D1474-06	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0065	0.015 AL	0.0010	mg/L		05/02/22 1326	05/02/22 1452	MMC

<b>Client Sample ID:</b> 1-B	<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2022 9:50
<b>Lab Sample ID:</b> J2D1474-07	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		05/02/22 1326	05/02/22 1457	MMC

<b>Client Sample ID:</b> 80	<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2022 10:01
<b>Lab Sample ID:</b> J2D1474-08	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0301	0.015 AL	0.0010	mg/L		05/02/22 1326	05/02/22 1458	MMC



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J2D1474

<b>Client Sample ID:</b> 141	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J2D1474-09		<b>Collection Date:</b> 04/20/2022 10:03

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0026	0.015 AL	0.0010	mg/L		05/02/22 1326	05/02/22 1459	MMC

<b>Client Sample ID:</b> 9-B	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J2D1474-10		<b>Collection Date:</b> 04/20/2022 10:14

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0200	0.015 AL	0.0010	mg/L		05/03/22 1449	05/04/22 1328	MMC

<b>Client Sample ID:</b> 24	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J2D1474-11		<b>Collection Date:</b> 04/20/2022 9:54

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0123	0.015 AL	0.0010	mg/L		05/02/22 1326	05/02/22 1500	MMC

<b>Client Sample ID:</b> 23	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J2D1474-12		<b>Collection Date:</b> 04/20/2022 9:53

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0072	0.015 AL	0.0010	mg/L		05/02/22 1326	05/02/22 1502	MMC



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J2D1474

<b>Client Sample ID:</b> 66	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J2D1474-13		<b>Collection Date:</b> 04/20/2022 10:12

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0067	0.015 AL	0.0010	mg/L		05/02/22 1326	05/02/22 1504	MMC

<b>Client Sample ID:</b> 5-B	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J2D1474-14		<b>Collection Date:</b> 04/20/2022 9:56

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		05/02/22 1326	05/02/22 1505	MMC

<b>Client Sample ID:</b> 10-B	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J2D1474-15		<b>Collection Date:</b> 04/20/2022 10:15

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0046	0.015 AL	0.0010	mg/L		05/02/22 1326	05/02/22 1507	MMC

<b>Client Sample ID:</b> 36-B	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J2D1474-16		<b>Collection Date:</b> 04/20/2022 10:52

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0039	0.015 AL	0.0010	mg/L		05/02/22 1326	05/02/22 1508	MMC



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J2D1474

<b>Client Sample ID:</b> 12-B	<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2022 10:17
<b>Lab Sample ID:</b> J2D1474-17	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0095	0.015 AL	0.0010	mg/L		05/02/22 1326	05/02/22 1513	MMC

<b>Client Sample ID:</b> 14-B	<b>Collected By:</b> client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2022 10:21
<b>Lab Sample ID:</b> J2D1474-18	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0142	0.015 AL	0.0010	mg/L		05/02/22 1326	05/02/22 1514	MMC

<b>Client Sample ID:</b> 4-B	<b>Collected By:</b> client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2022 9:52
<b>Lab Sample ID:</b> J2D1474-19	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0013	0.015 AL	0.0010	mg/L		05/02/22 1326	05/02/22 1515	MMC

<b>Client Sample ID:</b> 3	<b>Collected By:</b> Client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2022 9:43
<b>Lab Sample ID:</b> J2D1474-20	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0084	0.015 AL	0.0010	mg/L		05/02/22 1326	05/02/22 1517	MMC



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J2D1474

<b>Client Sample ID:</b> 133	<b>Collected By:</b> client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2022 9:52
<b>Lab Sample ID:</b> J2D1474-21	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0112	0.015 AL	0.0010	mg/L		05/03/22 1136	05/03/22 1150	MMC

<b>Client Sample ID:</b> 21-B	<b>Collected By:</b> client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2022 10:34
<b>Lab Sample ID:</b> J2D1474-22	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0048	0.015 AL	0.0010	mg/L		05/03/22 1136	05/03/22 1153	MMC

<b>Client Sample ID:</b> 3-B	<b>Collected By:</b> client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2022 9:52
<b>Lab Sample ID:</b> J2D1474-23	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0173	0.015 AL	0.0010	mg/L		05/03/22 1136	05/03/22 1155	MMC

<b>Client Sample ID:</b> 34-B	<b>Collected By:</b> client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2022 10:50
<b>Lab Sample ID:</b> J2D1474-24	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0025	0.015 AL	0.0010	mg/L		05/03/22 1136	05/03/22 1156	MMC



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J2D1474

<b>Client Sample ID:</b> 19-B	<b>Collected By:</b> client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2022 10:26
<b>Lab Sample ID:</b> J2D1474-25	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		05/03/22 1136	05/03/22 1157	MMC

<b>Client Sample ID:</b> 101	<b>Collected By:</b> client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2022 10:30
<b>Lab Sample ID:</b> J2D1474-26	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0080	0.015 AL	0.0010	mg/L		05/03/22 1136	05/03/22 1158	MMC

<b>Client Sample ID:</b> 67	<b>Collected By:</b> client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2022 10:11
<b>Lab Sample ID:</b> J2D1474-27	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0165	0.015 AL	0.0010	mg/L		05/03/22 1136	05/03/22 1203	MMC

<b>Client Sample ID:</b> 54	<b>Collected By:</b> client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2022 10:19
<b>Lab Sample ID:</b> J2D1474-28	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0098	0.015 AL	0.0010	mg/L		05/03/22 1136	05/03/22 1204	MMC



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J2D1474

<b>Client Sample ID:</b> 146	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> client
<b>Lab Sample ID:</b> J2D1474-29		<b>Collection Date:</b> 04/20/2022 10:47

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0247	0.015 AL	0.0010	mg/L		05/03/22 1136	05/03/22 1206	MMC

<b>Client Sample ID:</b> 147	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> client
<b>Lab Sample ID:</b> J2D1474-30		<b>Collection Date:</b> 04/20/2022 10:48

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0093	0.015 AL	0.0010	mg/L		05/03/22 1136	05/03/22 1207	MMC

<b>Client Sample ID:</b> 6-B	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> client
<b>Lab Sample ID:</b> J2D1474-31		<b>Collection Date:</b> 04/20/2022 9:58

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0014	0.015 AL	0.0010	mg/L		05/03/22 1136	05/03/22 1208	MMC

<b>Client Sample ID:</b> 116	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> client
<b>Lab Sample ID:</b> J2D1474-32		<b>Collection Date:</b> 04/20/2022 10:45

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0040	0.015 AL	0.0010	mg/L		05/03/22 1136	05/03/22 1210	MMC





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J2D1474

<b>Client Sample ID:</b> 16-B	<b>Collected By:</b> client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2022 10:23
<b>Lab Sample ID:</b> J2D1474-33	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0143	0.015 AL	0.0010	mg/L		05/03/22 1136	05/03/22 1212	MMC

<b>Client Sample ID:</b> 11-B	<b>Collected By:</b> client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2022 10:15
<b>Lab Sample ID:</b> J2D1474-34	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0192	0.015 AL	0.0010	mg/L		05/03/22 1136	05/03/22 1213	MMC

<b>Client Sample ID:</b> 18-B	<b>Collected By:</b> client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2022 10:25
<b>Lab Sample ID:</b> J2D1474-35	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		05/03/22 1136	05/03/22 1214	MMC

<b>Client Sample ID:</b> 2-B	<b>Collected By:</b> client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2022 9:51
<b>Lab Sample ID:</b> J2D1474-36	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		05/03/22 1136	05/03/22 1220	MMC



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J2D1474

<b>Client Sample ID:</b> 8-B	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J2D1474-37		<b>Collection Date:</b> 04/20/2022 9:59

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.015 AL	0.0010	mg/L		05/03/22 1136	05/03/22 1221	MMC

<b>Client Sample ID:</b> 131	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J2D1474-38		<b>Collection Date:</b> 04/20/2022 10:46

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0083	0.015 AL	0.0010	mg/L		05/03/22 1136	05/03/22 1223	MMC

<b>Client Sample ID:</b> 31-B	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> client
<b>Lab Sample ID:</b> J2D1474-39		<b>Collection Date:</b> 04/20/2022 9:59

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0186	0.015 AL	0.0010	mg/L		05/03/22 1136	05/03/22 1224	MMC

<b>Client Sample ID:</b> 20-B	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> client
<b>Lab Sample ID:</b> J2D1474-40		<b>Collection Date:</b> 04/20/2022 10:33

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0045	0.015 AL	0.0010	mg/L		05/03/22 1136	05/03/22 1225	MMC



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J2D1474

<b>Client Sample ID:</b> 15-B	<b>Collected By:</b> client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2022 10:22
<b>Lab Sample ID:</b> J2D1474-41	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0258	0.015 AL	0.0010	mg/L		05/03/22 1213	05/03/22 1318	MMC

<b>Client Sample ID:</b> 33-B	<b>Collected By:</b> client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2022 10:50
<b>Lab Sample ID:</b> J2D1474-42	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0159	0.015 AL	0.0010	mg/L		05/03/22 1213	05/03/22 1322	MMC

<b>Client Sample ID:</b> 24-B	<b>Collected By:</b> client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2022 10:41
<b>Lab Sample ID:</b> J2D1474-43	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0127	0.015 AL	0.0010	mg/L		05/03/22 1213	05/03/22 1323	MMC

<b>Client Sample ID:</b> 29-B	<b>Collected By:</b> client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2022 10:46
<b>Lab Sample ID:</b> J2D1474-44	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0385	0.015 AL	0.0010	mg/L		05/03/22 1213	05/03/22 1324	MMC



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J2D1474

<b>Client Sample ID:</b> 32-B	<b>Collected By:</b> client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2022 10:49
<b>Lab Sample ID:</b> J2D1474-45	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0121	0.015 AL	0.0010	mg/L		05/03/22 1213	05/03/22 1326	MMC

<b>Client Sample ID:</b> 115	<b>Collected By:</b> client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2022 10:40
<b>Lab Sample ID:</b> J2D1474-46	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0845	0.015 AL	0.0010	mg/L		05/03/22 1449	05/04/22 1329	MMC

<b>Client Sample ID:</b> 26-B	<b>Collected By:</b> client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2022 10:42
<b>Lab Sample ID:</b> J2D1474-47	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0217	0.015 AL	0.0010	mg/L		05/03/22 1213	05/03/22 1327	MMC

<b>Client Sample ID:</b> 22-B	<b>Collected By:</b> client
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 04/20/2022 10:38
<b>Lab Sample ID:</b> J2D1474-48	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0011	0.015 AL	0.0010	mg/L		05/03/22 1213	05/03/22 1332	MMC



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J2D1474

<b>Client Sample ID:</b> 53	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> client
<b>Lab Sample ID:</b> J2D1474-49		<b>Collection Date:</b> 04/20/2022 10:19

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0385	0.015 AL	0.0010	mg/L		05/03/22 1213	05/03/22 1333	MMC

<b>Client Sample ID:</b> 30-B	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> client
<b>Lab Sample ID:</b> J2D1474-50		<b>Collection Date:</b> 04/20/2022 10:51

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0172	0.015 AL	0.0010	mg/L		05/03/22 1213	05/03/22 1334	MMC

<b>Client Sample ID:</b> 17-B	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> client
<b>Lab Sample ID:</b> J2D1474-51		<b>Collection Date:</b> 04/20/2022 10:24

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0034	0.015 AL	0.0010	mg/L		05/03/22 1213	05/03/22 1336	MMC

<b>Client Sample ID:</b> 28-B	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J2D1474-52		<b>Collection Date:</b> 04/20/2022 10:42

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0013	0.015 AL	0.0010	mg/L		05/03/22 1213	05/03/22 1337	MMC



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J2D1474

<b>Client Sample ID:</b> 35-B	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> Client
<b>Lab Sample ID:</b> J2D1474-53		<b>Collection Date:</b> 04/20/2022 10:51

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0066	0.015 AL	0.0010	mg/L		05/03/22 1213	05/03/22 1339	MMC

<b>Client Sample ID:</b> 71	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> client
<b>Lab Sample ID:</b> J2D1474-54		<b>Collection Date:</b> 04/20/2022 10:09

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0143	0.015 AL	0.0010	mg/L		05/03/22 1213	05/03/22 1340	MMC

<b>Client Sample ID:</b> 35	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> client
<b>Lab Sample ID:</b> J2D1474-55		<b>Collection Date:</b> 04/20/2022 10:24

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0086	0.015 AL	0.0010	mg/L		05/03/22 1213	05/03/22 1342	MMC

<b>Client Sample ID:</b> 25-B	<b>Sample Matrix:</b> Drinking Water	<b>Collected By:</b> client
<b>Lab Sample ID:</b> J2D1474-56		<b>Collection Date:</b> 04/20/2022 10:42

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<b>0.0185</b>	0.015 AL	0.0010	mg/L		05/03/22 1213	05/03/22 1343	MMC



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J2D1474

Client Sample ID: 75	Collected By: client
Sample Matrix: Drinking Water	Collection Date: 04/20/2022 10:08
Lab Sample ID: J2D1474-57	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0332	0.015 AL	0.0010	mg/L		05/03/22 1213	05/03/22 1347	MMC

Client Sample ID: 100	Collected By: client
Sample Matrix: Drinking Water	Collection Date: 04/20/2022 10:29
Lab Sample ID: J2D1474-58	

Analyses Performed by: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0219	0.015 AL	0.0010	mg/L		05/03/22 1213	05/03/22 1348	MMC

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL: US EPA Action Level
- mg/L: Milligrams per Liter
- RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville 11549	New York State Department of Health
Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795	New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.

Reviewed and Approved By:

Shannon Weeks  
Customer Relationship Coordinator  
Reported: 05/16/2022 10:13

# Microbac Laboratories, Inc.

## CHAIN OF CUSTODY

Samples must be returned on

MNY Workorder #


EK  
 4/20/22

Page 16 of 18

Client Information				Billing/Invoice:		Analysis Requested						Receiving Info (Lab Use Only)	
Name:	Jeff/Lew Boces											Ice:	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
Address:	20104 NYS Route 3											Cooler:	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
Contact:	Health/Safety Dept.											Sample Temp:	
Phone:	315-779-7000											Cooler Seal:	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
Project:	Lead Testing			PO#:								Pickup:	YES <input type="checkbox"/> NO <input type="checkbox"/>
Quote ID:												Dropoff:	C <input type="checkbox"/> W <input type="checkbox"/>
Rush TAT Bus. Days:	<2 2-5 5-7 7-10			Date Req.:								Accepted?	YES <input type="checkbox"/> NO <input type="checkbox"/>
Carbon Copy:	Yes											Container Material	
Email Results:	Yes rfilley@boces.com, fhauck@boces.com, lshaw@boces.com											Container Size (in MI)	
Fax Results:	Yes											Preservative	
Sample Information				Matrix		Number of Containers for Analysis Requested						Comments/Field Data	
Description/Location	Date	Time	Type										
1 7-B	4/20/22	10:01	DW										
2 13-B		10:20											
3 9		9:44											
4 23-B		10:40											
5 27-B		10:42											
6 92		10:00											
7 1-B		9:50											
8 80		10:01											
9 141		10:03											
10 9-B		10:14											
11 24		9:54											
12 23		9:53											
13 66		10:12											
14 5-B		9:56											
15 10-B		10:15											
16 36-B		10:52											
17 12-B		10:17											
18 14-B		10:21											
19 4-B		9:52											
20 3	✓	9:43											
Print Name and Company				Date/Time		Comments							
Sampled: Linda Shaw				4/20 2PM		1 OF 3						FV SP	
Received: [Signature]				4/20/22 11:17									
Received:													

Total Lead (EPA 200.8)

Plastic  
 250 ml  
 HNO3





EK  
 4/20/22

# Microbac Laboratories, Inc.

## CHAIN OF CUSTODY

Samples must be returned on


MNY Workorder #

Client Information				Billing/Invoice:		Analysis Requested						Receiving Info (Lab Use Only)	
Name:	Jeff/Lew Boces											Ice:	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
Address:	20104 NYS Route 3											Cooler:	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
Contact:	Health/Safety Dept.											Sample Temp:	
Phone:	315-779-7000											Cooler Seal:	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
Project:												Pickup:	YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>
Quote ID:	Lead Testing		PO#:								Dropoff:	C <input type="checkbox"/> W <input type="checkbox"/>	
Rush TAT Bus. Days:	<2 2-5 5-7 7-10		Date Req.:								Accepted?	YES <input type="checkbox"/> NO <input type="checkbox"/>	
Carbon Copy:	Yes											Container Material	
Email Results:	Yes			rfillay@boces.com, fhauck@boces.com, lshaw@boces.com								Container Size (in MI)	
Fax Results:	Yes											Preservative	
Sample Information				Matrix Type		Number of Containers for Analysis Requested						Comments/Field Data	
Description/Location	Date	Time	Matrix Type										
1 133	4/20/22	9:52	DW										
2 21-B		10:34											
3 3-B		9:52											
4 34-B		10:50											
5 19-B		10:26											
6 101		10:30											
7 67		10:11											
8 54		10:19											
9 146		10:47											
10 147		10:48											
11 6-B		9:58											
12 116		10:45											
13 16-B		10:23											
14 11-B		10:15											
15 18-B		10:25											
16 2-B		9:51											
17 8-B		9:59											
18 131		10:46											
19 31-B		9:59											
20 20-B		10:33											
Print Name and Company				Date/Time		Comments							
Sampled: Linda Shaw				4/20 2PM		2 OF 3							
Received: S Deuter				4.20.22 11:17		LJ							

Total Lead (EPA 200.8)

Plastic  
250 ml  
HNO3

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCE  
 PM: Shannon Weeks



Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. Reviewing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

EK  
 4/20/22

# Microbac Laboratories, Inc.

## CHAIN OF CUSTODY

Samples must be returned on  
 MNY Workorder #

Client Information		Billing/Invoice:	
Name:	Jef/Lew Boces		
Address:	20104 NYS Route 3		
Contact:	Health/Safety Dept.		
Phone:	315-779-7000		
Project:			
Quote ID:	Lead Testing	PO#:	
Rush TAT Bus. Days:	<2 2-5 5-7 7-10	Date Req.:	
Carbon Copy:	Yes		
Email Results:	Yes	rfiley@boces.com, fhauck@boces.com, lshaw@boces.com	
Fax Results:	Yes		


Analysis Requested					
Total Lead (EPA 200.8)					
Plastic					
250 ml					
HNO3					

Receiving Info (Lab Use Only)	
Ice:	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
Cooler:	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
Sample Temp:	
Cooler Seal:	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
Pickup:	YES <input type="checkbox"/> NO <input type="checkbox"/>
Dropoff:	C <input type="checkbox"/> W <input type="checkbox"/>
Accepted?	YES <input type="checkbox"/> NO <input type="checkbox"/>

Sample Information				Matrix
Description/Location	Date	Time	Type	Type
1 15-B	4/20/22	10:22	DW	
2 33-B		10:50		
3 24-B		10:41		
4 29-B		10:46		
5 32-B		10:49		
6 115		10:40		
7 26-B		10:42		
8 22-B		10:38		
9 53		10:19		
10 30-B		10:51		
11 17-B		10:24		
12 28-B		10:43		
13 35-B		10:51		
14 71		10:09		
15 35		10:24		
16 25-B		10:42		
17 75		10:08		
18 100		10:29		
19				
20				

Container Material	
Container Size (in ml)	
Preservative	

Number of Containers for Analysis Requested					
1					

Comments/Field Data	
	

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCE  
 PM: Shannon Weeks

Print Name and Company		Date/Time	Comments
Sampled:	Linda Shaw	4/20 2pm	
Received:	J. Dexter	4.20.22 11:17	3 OF 3
Received:			

JEF  
 SD

*Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. Reviewing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.*